

NOTES:

 REPRESENTS WHAT IS
 CONTAINED IN KIT

MAKE SURE YOU INSTALL
 THE "IN" AND "OUT" PORTS
 IN CORRECT LOCATIONS

THE 1 LB CHECK VALVE
 HAS AN ARROW POINTING IN
 THE DIRECTION WHERE THE
 WATER FLOWS

THE FLOAT USES A 9/16"
 HOLE.

IF YOUR HOUSE PRESSURE
 IS BELOW 40 PSI, THE
 WASTE WATER WILL NOT
 SHUT OFF WITH THIS KIT.
 IF THIS HAPPENS, YOU NEED
 TO PURCHASE A BOOSTER
 PUMP OR AN LLC.

INFORMATION

PROJECT: INSTALLATION FOR FLC
 ON RO & RODI SYSTEMS

DATE: 5-14-07

SCALE: N.T.S

The contents of this drawing are the sole property of SpectraPure . No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise without the prior written permission of SpectraPure . 2007

REVISIONS

DATE:	REV #

SHEET #

1/1

